



# OFFICE OF THE CORPORATION OF THE CITY, NAGPUR

Chhatrapati Shivaji Maharaj Prashashkiya Bhavan, Mahanagar Palika, Civil Lines, Nagpur-440 001

Ph. No.: 0712-2567777

Fax No.: 0712-2561584

No.: F.E.S./3204/C.F.O.

Date: 12.05.2023

To,

The Secretary,  
Viveksheel Mitra Pariwar Sanshtha  
St. Paul Public school  
Kh. No.15, P.H. No 36 Mouza- Dhamna,  
Ta. Dist. Nagpur.

Sub:- Fire Fitness Certificate only for existing Ground to 2<sup>nd</sup> Floor.

Ref:- 1) Your Application dated 02/03/2023 for fire fitness Certificate.  
2) Licensed Agency "B" Certificate on dated 06/02/2023

Fire Fitness Certificate is hereby granted to the existing Ground to 2<sup>nd</sup> floors of Educational Building with proposed Ground to 2<sup>nd</sup> Floors, Height 10.95 mtr & Super Built up area 4392.399 Sq.mtr. Viveksheel Mitra Pariwar, St. Paul Public school, kh No.15, P.H. No.36 Mouza-Dhamna Ta. Dist. Nagpur

This fire Fitness Certificate for existing Ground to 2<sup>nd</sup> Floors is issued on the basis of the inspection report of Deputy Chief Fire Officer, Fire & Emergency Service, Sakkardara Fire Station dated 08/05/2023 regarding fire fighting equipment being in good repair and efficient condition during the time of inspection and "B" Certificate dated 06.02.2023 by licensed Agency Named Gajanan Enterprises Agencies ( License No. MFS-LA/RP-0241, LA/RF-0209/LA/RD-0206) regarding the maintenance of the Fire prevention & Life Safety measures in said building.

As per the Maharashtra Fire Prevention and life safety measures Act 2006 the Owner/occupier of the building shall have to submit "B" Certificate by Licensed Agency in the month of January and July to this office

Chief Fire Officer  
Fire & Emergency Service  
Mpl Corporation Nagpur

Copy to-1) The Building Engg (ADTPO  
N.I.T/N.M.C. Nagpur  
2) Deputy/Chief Fire Officer  
Sakkardara Fire Station

PRINCIPAL

ST. PAUL PUBLIC SCHOOL  
DHAMNA (CHIKNA) TA & DIST. NAGPUR

DIRECTOR

ST. PAUL PUBLIC SCHOOL  
DHAMNA (CHIKNA) TA & DIST. NAGPUR